

Number	23-001834-PR01 (NW-C01-02-en-01)
Owner	Air-Lux Technik AG Breitschachenstrasse 52 9032 Engelburg/SG Schweiz
Product	External pedestrian doorset
Designation	System: AL PD 75
Details	Manufacturer Air-Lux Technik AG, - Engelburg/SG; Material Aluminium system with thermal break; Overall dimensions (W x H) 2000 mm x 3000 mm; Closing condition closed and locked; Lock: Motorised power cam bolt; Designation EffEff 842-SA - Q41
Special features	Pivot door

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C2/B2

Watertightness according to EN 12208:1999-11



Class: 9A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

20.04.2023



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Joachim Berkensträter
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
(e.g. DIN EN)

Test report: 23-001834-PR01 PB-
C01-02-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 689-B3D6B